

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 3063

Dated: 04/06/2025

It is certified that an inspection team headed by Anuj Kumar, Lab Chemist (Name of Officers with designation) from Uttar Pradesh Jal Nigam (Rural), Pilibhit PHED inspected the Happy Blue Bird Public School, Hempur, Bilsanda, Pilibhit, Uttar Pradesh (Name & Address of the school) on 29/05/2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. PIL/25/05/3063 dated 30.05.2025 Of Uttar Pradesh Jal Nigam (Rural), Pilibhit (PHED Lab) certified that the Happy Blue Bird Public School, Hempur, Bilsanda, Pilibhit, Uttar Pradesh has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 30.11.2025.

Signature with Seal: .....  
Name : Manish Gangwar  
Designation : Executive Engineer  
Name & Address of the Office / Department: .....

Executive Engineer  
Division Office  
U P Jal Nigam (Gramin)  
Pilibhit

To

MANAGER

Happy Blue Bird Public School,  
Hempur, Bilsanda, Pilibhit, Uttar  
Pradesh

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies.

# District Level Water Testing Laboratory (Uttar Pradesh Jal Nigam, Pilibhit)

Address: Office of Executive Engineer, Construction Division,  
U.P Jal Nigam In front of district veterinary Hospital, Tanakpur road, Pilibhit. Pin- 262001  
(NABL Certified Laboratory)



## WATER ANALYSIS REPORT

Rept. No	3063	Date:	30-05-2025
<b>Customer Details</b>			
Office Name and Address	Happy Blue Bird Public School, Hempur, Bilsanda, Pilibhit.		
Ref Letter No & Date	Application by customer Date- 29-05-2025		
<b>Sample Description</b>			
District	Pilibhit	Block	Bilsanda
Gram Panchayat/Nagar Panchayat	Hempur	Village/Ward No.	Hempur
Habitation	Hempur	Location	Happy Blue Bird Public School
Water Source	RO water	Sample Code	PIL/25/05/3063
Date & Time of Sample Collection	29-05-2025 9:30AM	Sample Collector Name	Saurav Shukla
Receiving Date & Time	29-05-2025 1:20PM	Sample Receiver	Sanjeev Kumar
Water Sample Type	Drinking water	Quantity of Sample	1000ml

### Environmental Condition

Temperature	24°C ±3°C	Humidity	54% ±15%
Analysis Date	30-05-2025		

### Technical Data of Analysis

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Chloride	10.99	mg/l	250	1000	IS 3025 (Part 32) : 2019
2	Fluoride	0.091	mg/l	1	1.5	APHA 24th Edition 4500-F <sup>-</sup> Method C (Electrode Method) : 2023
3	Iron	0.080	mg/l	1	No relaxation	IS 3025 (Part 53) : 2019
4	Nitrate	1.89	mg/l	45	No relaxation	APHA 24th Edition 4500-NO <sub>3</sub> <sup>-</sup> Method B (UV Screening Method):2023
5	pH	7.58	NA	6.5-8.5	No relaxation	IS 3025 (Part 11) : 2022
6	Sulphate	4.18	mg/l	200	400	APHA 24th Edition 4500-SO <sub>4</sub> <sup>-2</sup> Method E (Turbidimetric Method) : 2023
7	TDS	152	mg/l	500	2000	IS 3025 (Part 16) : 2023
8	Total Alkalinity	100	mg/l	200	600	IS 3025 (Part 23) : 2023
9	Total Hardness	68	mg/l	200	600	IS 3025 (Part 21) : 2019
10	Turbidity	1.42	NTU	1	5	IS 3025 (Part 10) : 2023

Note 1. This Certificate refers only to the particular sample(s) submitted for testing.

2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 2-3 days (in case of non perishable items only) from the date of issue of tests reports unless.

*Sanjeev*  
Analysis by  
Sanjeev Kumar  
(Lab Assistant)

*M*  
Authorized Signatory  
Sanjeev Kumar  
U.P. (Chemist) Jal Nigam  
PILIBHIT

\*\*\*End of the Report\*\*\*





**District Level Water Testing Laboratory  
(Uttar Pradesh Jal Nigam, Pilibhit)**

Address: Office of Executive Engineer, Construction Division,  
U.P Jal Nigam In front of district veterinary Hospital, Tanakpur road, Pilibhit. Pin- 262001

**WATER ANALYSIS REPORT**

Rept. No	3063	Date:	30-05-2025			
<b>Customer Details</b>						
Office Name and Address	Happy Blue Bird Public School, Hempur, Bilsanda, Pilibhit.					
Ref Letter No & Date	Application by customer Date- 29-05-2025					
<b>Sample Description</b>						
District	Pilibhit	Block	Bilsanda			
Gram Panchayat/Nagar Panchayat	Hempur	Village/Ward No.	Hempur			
Habitation	Hempur	Location	Happy Blue Bird Public School			
Water Source	RO water	Sample Code	PIL/25/05/3063			
Date & Time of Sample Collection	29-05-2025 9:30AM	Sample Collector Name	Saurav Shukla			
Receiving Date & Time	29-05-2025 1:20PM	Sample Receiver	Sanjeev Kumar			
Water Sample Type	Drinking water	Quantity of Sample	1000ml			
<b>Environmental Condition</b>						
Temperature	24°C ±3°C	Humidity	54% ±15%			
Analysis Date	30-05-2025					
<b>Technical Data of Analysis</b>						
Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Total Coliform	0	CFU	No relaxation	-	APHA 23 <sup>rd</sup> Edition :2017 (IS 10500)
2	E .Coli	0	CFU	No relaxation	-	APHA 23 <sup>rd</sup> Edition :2017 (IS 10500)
<p>Note 1. This Certificate refers only to the particular sample(s) submitted for testing.</p> <p>2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.</p> <p>3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.</p> <p>4. Sample will be stored up to 2-3 days (in case of non perishable items only) from the date of issue of tests reports unless.</p>						
<p style="text-align: right;"><b>Microbiologist</b> U.P. JAL NIGAM Analysis by Disst. Water Suresh Kumar (Microbiologist)</p>						

\*\*\*End of the Report\*\*\*